



Certificate of Continued Compliance 12229050/AA/04



Issued 20-07-2022
Expiry date 20-07-2026

Replaces 12229050/AA/03
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: Internal Warning device
Trademark: CQR Security
Type designation: SO/ALTO*/G/S5
Hardware / Software: YP-2T5Q3 / -

Placed on the market under the name or trademark of:

Name of the manufacturer: CQR Security
Address: Pasture Road 125
City: CH46 4TH MORETON
Country: United Kingdom of Great Britain and Northern Ireland

This certificate is granted to:

Name of the certificate holder: CQR Security
Address: Pasture Road 125
City: CH46 4TH MORETON
Country: United Kingdom of Great Britain and Northern Ireland

Ron Scheepers
Managing director

This certificate has THREE Annexes.

Telefication B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Type designation:

SO/ALTO/*/G/S5

where * is WH for White or BR for Brown

Security Grade: 3

Environmental Class: II

Equipment Class: Fixed

Warning Device Type: Internal

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

Electromagnetic emission and safety aspects are not covered by this certificate.

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: 20113829800rev 2.0, 15 August 2012
- Telefication B.V.: P000125726-001-Ver.1.00, 24 June 2022

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-4

April, 2019

Applied Standards

EN 50130-5

June, 2011

EN 50130-4+A1

October, 2014

EN 50131-1+A1+A2+A3

June, 2020

The product as described in this certificate includes the following type designations

- | | |
|------------------------|-------------------------|
| - Product description: | Internal Warning device |
| - Trademark: | CQR Security |
| - Type designation: | SO/ALTO*/G/S5 |
| - Hardware version: | YP-2T5Q3 |
| - Software version: | - |