



The mentioned product complies with the mentioned test requirement

Intertek LSS Scheme

Tick Mark Certificate

22LHK1150-01

This is to certify that:

MG5050+, SP6000+, SP5500+ Alarm Panels

Is/are in conformity with the following standard(s):

MG5050+: EN50131-1:2006+A2:2017, EN50131-3:2009, EN50131-5-3:2017, EN50136-1:2012+A1:2018, EN50136-2:2013, EN50131-6:2017

SP6000+, SP5500+: EN50131-1:2006+A2:2017, EN50131-3:2009, EN50136-1:2012+A1:2018, EN50136-2:2013,

EN50131-6:2017

Report Number(s): See ANNEX No.2

Paradox Security Systems Ltd.

780 Industrial Blvd. St-Eustache, Quebec, Canada

and is authorised to use the Intertek Tick Mark for the LSS Scheme on the above mentioned product(s)

This certificate is valid until:

17-Aug-2027

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

Limitations:		
No limitations apply	Certification Body:	ITCL
	LSS Reference:	LSS 1139
	Issued Date:	18-Aug-2023



Signed on behalf of Intertek, located at Leatherhead, United Kingdom

Certification Officer

S. Yetheren Hen.

0010 S Yathunanthan

Reference: LSS 1139 Page 1 (see model details on page 2)





Intertek LSS Scheme

Tick Mark Certificate

22LHK1150-01

The mentioned product complies with the mentioned test requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 1

Brand and Ty	ype/Model	Description	Factory Code
MG5050+ (43	33 MHz)	Security Alarm, Control Panel	PARADOCA.01
MG5050+ (86	68 MHz)	Security Alarm, Control Panel	PARADOCA.01
SP6000+		Security Alarm, Control Panel	PARADOCA.01
SP5500+		Security Alarm, Control Panel	PARADOCA.01

Security Grade: 2 Environmental Class: II

ATS Class: MG5050+ is SP4, SP6000+ and SP5500+ are SP2

Number of zone options: MG5050+ and SP5500+ has 5 onboard zones, SP6000+ has 8 onboard zones

Rating: 16.5 VAC (50 or 60 Hz)

ANNEX No. 2

Report Numbers(s):

MG5050+: 452398-1TRFEMC, 452398-2TRFEMC, 452398-3TRFEMC, 453056-1TRFEMC, PARAS_EN50136.44733, PARENV_EN.44733, PARIAS_EN50131-3.44733, PARIAS_EN50131-6.44733 SP6000+, SP5500+: PARAS_EN50136.45821, PAREMC_45821, PARENV_EN.45821, PARIAS_EN50131-3.45821, PARIAS_EN50131-6.45821, PARSAF_Delta.EN.45821

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Reference: LSS 1139 Page 2 of 2